

APPENDIIX-L
FORM "S"
[SEE RULE 87(5)]

FIRE AUDIT REPORT

Year: 2023-24

To,
The Principal
Sarojini Naidu Goverment Girls PG
(Autonomus) College, Shivaji Nagar
Bhopal, Madhya Pradesh 462016

Sir,
Sub:-Submission Of Fire Audit Report Of Building Sarojini Naidu Goverment Girls PG (Autonomus)
College, Shivaji Nagar Bhopal Madhya Pradesh 462016

Sir,
I Shubham Jain, B.E Fire Technology & Safety, Authorized Fire Engineer/Consultant By Urban
Development, Bhopal Madhya Pradesh Have Inspected Your Building /Premises On (dated) 28/06/2023
Checked All Fire Equipment /Installations And Have Completed The Fire Audit Of Said Building
/Premises. For Which Fire Noc No... Is Not Available.

OCCUPANCY: EDUCATIONAL BUILDING

Details of fire system installed areas below:

| Sr No | Particular | Available/ Installed or not installed as per requirement (give Comments) | Comments for working of system (attached details, if needed) |
|----------|--|--|--|
| 1 | Access | Available | 02Nos Access By Main Road |
| 2 | Wet Riser | Not Available | Not Required |
| 3 | Down Comer | Not Available | Required As Per NBC Part 4 2016 |
| 4 | Hose Reel | Not Available | Required As Per NBC Part 4 2016 |
| 5 | Automatic sprinkler system | Not Available | Not Required |
| 6 | Yard Hydrant | Not Available | Required |
| 7 | Underground Tank with draw off connection | Available | Yes Available 5500LTRS Draw off Connection Is Not Available |
| 8 | Terrace Tanks | Available | Yes Available 27500Ltrs Available |
| 9 | Fire Pump | Not Available | Not Required |
| 10 | Terrace Pump | Not Available | Required As Per NBC Part 4 |

| | | | 2016 |
|----|--|--------------------------|--|
| 11 | First Aid Fire Fighting Appliances | Available TOTAL 15NOS | 5KG ABC TYPE FIRE EXTINGUISHER :- 3NOS 6KG ABC TYPE FIRE EXTINGUISHER :- 4NOS 4.5KG CO2 TYPE FIRE EXTINGUISHER :- 8NOS More Extinguishers In Each Block Required As Per NBC Part-4 2016 |
| 12 | Pressurized System | Not Available | Natural ventilated |
| 13 | Auto Detection System | Not Available | Not Required |
| 14 | Manual operated Electrical Fire Alarm System | Not Available | Not Required |
| 15 | P. A System with talk back Facility | Not Available | Not Required |
| 16 | Emergency Light | Not Available | Not Required |
| 17 | Auto D.G Set | Available | 10KVA Dg Set Available |
| 18 | Illuminated Exit Sign | Not Available | Required |
| 19 | Means of Escape | Available | Available 2nos Stair Available In Each Block |
| 20 | Compartmentation | Not Available | Not Required |
| 21 | MCB/ELCB/RCCB/MCCB | Available | MCB Are Installed At Electric Panel |
| 22 | Firemen Switch in Lift | Not Available | Required |
| 23 | Hose Boxes with Delivery Hose and Branch | Not Available | Required In Yard Area |
| 24 | Refuse Area | Not Available | Not Required |
| 25 | Any other Installation | CCTV Available | Found In Working Condition |

It is certified that the installed Fire System as given above are in working condition and Safe.

Date: 28/06/2023.

Note : Find out Some Point At the time of Visit.

ER. SHUBHAM JAIN
B.E. FIRE & SAFETY
LIC NO.07/BFB/2023
BHOPAL (M.P.)
ER. SHUBHAM JAIN
B.E. FIRE & SAFETY
LIC NO.07/BFB/2023
BHOPAL(M.P.)

1. Display Danger Board Near Electrical Panel Room.